

March 6, 2003

FOR INCLUSION ON TECHNICAL SPECIFICATION WEB PAGE

THE FOLLOWING EXAMPLE OF AN APPLICATION WAS PREPARED BY THE NRC STAFF TO FACILITATE THE USE OF THE CONSOLIDATED LINE ITEM IMPROVEMENT PROCESS (CLIIP). THE MODEL PROVIDES THE EXPECTED LEVEL OF DETAIL AND CONTENT FOR AN APPLICATION TO ADOPT TSTF-370 USING CLIIP. LICENSEES REMAIN RESPONSIBLE FOR ENSURING THAT THEIR ACTUAL APPLICATION FULFILLS THEIR ADMINISTRATIVE REQUIREMENTS AS WELL AS NRC REGULATIONS.

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

SUBJECT: PLANT NAME
DOCKET NO. 50-
APPLICATION FOR TECHNICAL SPECIFICATION IMPROVEMENT TO
EXTEND THE COMPLETION TIME FOR CONDITION B OF TECHNICAL
SPECIFICATION [3.5.1], "ACCUMULATORS," USING THE CONSOLIDATED
LINE ITEM IMPROVEMENT PROCESS

Gentlemen:

In accordance with the provisions of 10 CFR 50.90 of Title 10 of the *Code of Federal Regulations* (10 CFR), [LICENSEE] is submitting a request for an amendment to the technical specifications (TS) for [PLANT NAME, UNIT NOS.].

The proposed amendment would extend the completion time from 1 hour to 24 hours for Condition B of Technical Specification (TS) 3.5.1, "Accumulators." The change is consistent with NRC approved Industry/Technical Specification Task Force (TSTF) Standard Technical Specification Change Traveler, TSTF-370, "Risk Informed Evaluation of an Extension to Accumulator Completion Times for Westinghouse Plants." The availability of this technical specification improvement was announced in the *Federal Register* on [DATE OF NOTICE OF AVAILABILITY] as part of the consolidated line item improvement process (CLIIP).

Enclosure 1 provides a description of the proposed change and confirmation of applicability. Enclosure 2 provides the existing TS pages marked-up to show the proposed change. *[IF APPLICABLE: Enclosure 3 provides the existing TS Bases pages marked-up to reflect the proposed change (for information only). Changes to the TS Bases will be provided in a future update in accordance with the Bases Control Program.]* There are no new regulatory commitments associated with this proposed change.

[LICENSEE] requests approval of the proposed license amendment by [DATE], with the amendment being implemented [BY DATE OR WITHIN X DAYS].

In accordance with 10 CFR 50.91, a copy of this application, with enclosures, is being provided to the designated [STATE] Official.

I declare under penalty of perjury under the laws of the United States of America that I am authorized by [LICENSEE] to make this request and that the foregoing is true and correct. [Note that request may be notarized in lieu of using this oath or affirmation statement].

If you should have any questions regarding this submittal, please contact [].

Sincerely,

Name, Title

Enclosures: 1. Description and Assessment
 2. Proposed Technical Specification Changes
 3. Proposed Technical Specification Bases Changes (if applicable)

cc: NRR Project Manager
 Regional Office
 Resident Inspector
 State Contact

Description and Assessment

1.0 DESCRIPTION

The proposed License amendment extends the completion time from 1 hour to 24 hours for Condition B of Technical Specification (TS) 3.5.1, "Accumulators."

The changes are consistent with NRC approved Industry/Technical Specification Task Force (TSTF) Standard Technical Specification Change Traveler, TSTF-370, "Risk Informed Evaluation of an Extension to Accumulator Completion Times for Westinghouse Plants." The availability of this technical specification improvement was announced in the *Federal Register* on [DATE] as part of the consolidated line item improvement process (CLIIP).

2.0 ASSESSMENT

2.1 Applicability of Published Safety Evaluation

[LICENSEE] has reviewed the safety evaluation published on July 15, 2002 (67 FR 46542) as part of the CLIIP. This verification included a review of the NRC staff's evaluation as well as the supporting information provided to support TSTF-370 (i.e., WCAP-15049-A, "Risk-Informed Evaluation of an Extension to Accumulator Completion Times," dated May 18, 1999).

[LICENSEE] has concluded that the justifications presented in the TSTF proposal and the safety evaluation prepared by the NRC staff are applicable to [PLANT, UNIT NOS.] and justify this amendment for the incorporation of the changes to the [PLANT] Technical Specifications.

2.2 Optional Changes and Variations

[LICENSEE] is not proposing any variations or deviations from the technical specification changes described in TSTF-370 or the NRC staff's model safety evaluation published on July 15, 2002.

3.0 REGULATORY ANALYSIS

3.1 No Significant Hazards Determination

[LICENSEE] has reviewed the proposed no significant hazards consideration determination published on July 15, 2002 (67 FR 46542) as part of the CLIIP. [LICENSEE] has concluded that the proposed determination presented in the notice is applicable to [PLANT] and the determination is hereby incorporated by reference to satisfy the requirements of 10 CFR 50.91(a).

3.2 Verification and Commitments

There are no new regulatory commitments associated with this proposed change.

4.0 ENVIRONMENTAL EVALUATION

[LICENSEE] has reviewed the environmental evaluation included in the model safety evaluation published on July 15, 2002 (67 FR 46542) as part of the CLIIP. [LICENSEE] has concluded that the NRC staff's findings presented in that evaluation are applicable to [PLANT] and the evaluation is hereby incorporated by reference for this application.

PROPOSED TECHNICAL SPECIFICATION CHANGES (MARK-UP)

POSSIBLE CHANGES TO TS BASES PAGES

(Optional - Bases to be updated per TS Bases Control Program)

Distribution:

PUBLIC
PDIV-1 Reading File
RDennig
GHill

Accession Number: ML030640794
ADAMS Template:Nrr-106

File:C:\ORPCheckout\FileNET\ML030640794.wpd

OFC	NRR/DLPM/PM	NRR/DLPM/LA	NRR/DLPM/PDIV
NAME	W Reckley	M McAllister	H Berkow
DATE	3/4/03	3/4/03	3/6/03

OFFICIAL AGENCY RECORD